Wellhead Protection Plan
Part 2 Public Hearing

City Council Meeting
July 28, 2015

CITY OF TONKA BAY

WSB & Associates, Inc.

• Overview

- **Part I – Completed by MDH in June of 2011**
  - Delineates the Wellhead Protection Area (WHPA)
  - Determines the Drinking Water Supply Management Area (DWSMA)
  - Completes well and aquifer vulnerability assessment
    - DWSMA is Low Vulnerability
- **Part II – Must be approved by the MDH**
  - Evaluates Data Elements
  - Inventories Potential Contaminant Sources (Wells)
  - Develops Management Strategies
    - Goals, Objectives, Plan of Action, and Evaluation

CITY OF TONKA BAY

WSB & Associates, Inc.



• MDH Required Report Revisions

- **Remove the following potential contaminants:**
  - Hazardous Waste Management
  - Septic Systems
  - Storm Water Management
- **Add the following items:**
  - Prioritize unused wells for sealing
  - Investigate any un-located or Class V wells in DWSMA
  - Include the MDH IWMZ survey forms
  - Review and update the IWMZ with the assistance of MDH

• Next Steps

- Approve resolution to resubmit plan to the MDH
- WSB to submit Plan to MDH
- MDH shall review plan within 90 days of submittal
- Once Plan is approved:
  - Send letter to all local government units (within 60 days of approval)
  - Begin implementation of Plan action items (within 60 days of approval)

- Questions?